

Frederick Andrae, Architects

25 SOUTH ROYAL AVE.
Front Royal, VA 22630

tel: (540-635-5135)
fax: (540-635-5135)
e-mail: fandrae@embarqmail.com

TRANSMITTAL

Date **July 24, 2019**

Project No.

NORTH WARREN FIRE STATION #10

**266 ROCKLAND COURT
FRONT ROYAL, VA 22630**

Via

US Mail
Courier
Hand

E-mail

Fax

Website

To **All Potential Bidders**

For

Your Use

Your Approval
Review & Comment
Your Request

From **Fred Andrae**

Re **Request for Information #1**

Action Taken

Approved
Approved as Noted
Revise & Resubmit
As Noted

Copies	Date	No.	Description
--------	------	-----	-------------

	7-24-19		Bidding RFI #1
--	----------------	--	-----------------------

RFI #1 Question from Russell Roofing:

When using self-adhered underlayment, does the roof need to be vented?

RFI #1 Answer:

To maintain its warranties, McElroy does not require a vented roof when installing self-adhered underlayment.